

**C E R T I F I C A T E**  
of Conformity



Registration No.: AK 60020493 0001  
Report No.: 28101663 001

Holder: AILux S.r.l.  
Via Abbiati 18/A  
25125 Brescia BS  
Italia

Product: Switch  
Load disconnection peripheral unit

Identification: AILUX code UPDC H 500  
Test specification:  
Only for following tests of DRRPX02038:09/ 2003 ed.02:  
Prova di alimentazione, isolamento, impulso,  
prova a freddo, caldo secco, caldo umido regime stazionario,  
cambio di temperatura, 1,2/50 - 8/20 us,  
fast transients burst, damped oscillatory waves, conducted  
disturb. 150kHz to 80 MHz, electrostatic discharges,  
radiated electromagnetic fields

Tested acc. to: DRRPX02038 ed. 02/09.03

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Cologne, 29.01.2008



**TÜV Rheinland Product Safety GmbH - Am Grauen Stein - D-51105 Köln**